

17

OFFICE OF THE EXECUTIVE ENGINEER
RURAL ENGINEERING DEPARTMENT,
DIVISION MUZAFFARNAGAR

No. 135 /RED/2023-24

Dated : 25.04.2023

To,

The Principal,
Kendriya Vidyalaya,
Muzaffarnagar, Circular Road,
Muzaffarnagar.

Sub.: Safety Certificate in respect of School Building KV Muzaffarnagar.

Ref.: F.1385/17/KVMZN/2022-23/478 dated 01-02-2023.

Sir,

With reference to the above letter mentioned above it is to inform you that the school building of Kendriya Vidyalaya, Muzaffarnagar has been inspected on dated 10-04-2023 by me with Shri Naveed Iqbal, Assistant Engineer. This school building is a load bearing structure, if the structure is examined in consideration of new codes of Bureau of India Standards (BIS) and the latest seismological data, it is felt that the building is not totally earthquake resistant.

During the inspection of school building visually, no crack has been found in walls and slabs. Building is safe, in normal conditions, for students and staff.

School Building's structural audit to be reviewed after One year.

Yours faithfully,

Niraj 25/04/2023
(Niraj Kumar)

Executive Engineer
Rural Engineering Department,
Division Muzaffarnagar.

my
25/4/23